

Boilers		PL-C1000-BLR		PL-M2000-BLR		
Master / Follower logic (see note 1)		Follower		Follower		
Inputs	Supply Water Temperature (10K Type III)	✓		✓		
	Return Water Temperature (10K Type III)	✓		✓		
	Outside Air Temperature (10K Type III)	✓		✓		
	Proof of Pump 1	✓		✓		
	Proof of Pump 2	/		✓		
Outputs	Boiler Configuration		Staged Boiler	Modulating Boiler	Staged Boiler(s)	Modulating Boiler
	DO	Boiler Stage 1	✓	/	✓ (see note 2)	/
		Boiler Stage 2	✓	/	✓ (see note 2)	/
		Boiler Stage 3	/	/	✓ (see note 2)	/
		Boiler Stage 4	/	/	✓ (see note 2)	/
	AO	Pump 1	✓	✓	✓	✓
		Pump 2	✓	✓	/	/
		Pump 2	/	/	✓	✓
		Mixing Valve	✓	/	✓	/
		Modulating Boiler	/	✓	/	✓
		Backup Modulating boiler	/	/	/	✓
		Local Scheduling (see note 3)				Internal Clock, Schedule and Calendar

Notes:

1. A Master can have Followers beneath it; a Follower is a single zone/space.
2. Can be 4x single stage, 2x dual stage or single 4 stages boiler.
3. Scheduling can be configured either locally or through the RS485 network with the NC2000 Network Controller.