



# HARDWARE GUIDE

## VAV Zone Controller C1050 Series

---

Specifications and Operational Guide

---

[www.proloncontrols.com](http://www.proloncontrols.com) | [info@proloncontrols.com](mailto:info@proloncontrols.com)  
17 510, rue Charles, Suite 100, Mirabel, QC, J7J 1X9



# Table of Contents

|                                                                        |           |
|------------------------------------------------------------------------|-----------|
| <b>General Information .....</b>                                       | <b>4</b>  |
| PL-C1050 VAV Zone Controller .....                                     | 4         |
| Description.....                                                       | 4         |
| General Behaviour.....                                                 | 4         |
| <b>Operating Sequence .....</b>                                        | <b>5</b>  |
| General .....                                                          | 5         |
| Occupied Mode.....                                                     | 5         |
| Unoccupied Mode.....                                                   | 5         |
| <b>Selection Guide .....</b>                                           | <b>6</b>  |
| Flow Sensor.....                                                       | 6         |
| <b>Components .....</b>                                                | <b>7</b>  |
| Component Identification.....                                          | 7         |
| LEDs .....                                                             | 8         |
| Address Configuration for Networking ( <i>Modbus or BACnet</i> ) ..... | 8         |
| Airflow Sensor ( <i>Optional</i> ).....                                | 9         |
| <b>Damper Direction Configuration.....</b>                             | <b>10</b> |
| Input and Output Identification.....                                   | 11        |
| Room Sensors .....                                                     | 12        |
| Analog Room Sensor ( <i>PL-RS Series</i> ) .....                       | 12        |
| Digital Room Sensors .....                                             | 12        |
| Multi-Function Analog Input.....                                       | 14        |
| Supply Air Temperature Sensor ( <i>PL-CODS</i> ).....                  | 14        |
| Radiant Floor Slab Temperature Sensor .....                            | 14        |
| Discharge Air Temperature Sensor .....                                 | 15        |
| Digital Input.....                                                     | 16        |
| Occupancy originating from an External Timer.....                      | 16        |
| Standby mode originating from a Motion Detector .....                  | 16        |
| <b>Outputs .....</b>                                                   | <b>17</b> |
| Output Specifications .....                                            | 17        |
| Configuration of Digital Outputs 1 to 4.....                           | 18        |
| Typical Connection of the Triac Outputs 1 to 4 .....                   | 18        |
| Typical Connection of the Analog Output .....                          | 19        |
| <b>Power Source / Network .....</b>                                    | <b>20</b> |
| Power Source .....                                                     | 20        |
| Network Communication .....                                            | 20        |
| <b>Technical Specifications .....</b>                                  | <b>21</b> |
| <b>Compliance .....</b>                                                | <b>22</b> |
| FCC User Information .....                                             | 22        |
| Industry Canada .....                                                  | 22        |
| <b>Overall Dimensions .....</b>                                        | <b>23</b> |



## Table of Figures

|                                                                                 |    |
|---------------------------------------------------------------------------------|----|
| Figure 1 - Part Number.....                                                     | 6  |
| Figure 2 - Component Identification.....                                        | 7  |
| Figure 3 - LEDs Identification .....                                            | 8  |
| Figure 4 - Addressing Dipswitches.....                                          | 8  |
| Figure 5 - Airflow Sensor Inlets.....                                           | 9  |
| Figure 6 - Damper Configuration .....                                           | 10 |
| Figure 7 - Input and Output Identification.....                                 | 11 |
| Figure 8 - Typical Wiring of the PL-RSC Room Sensor to the Controller.....      | 12 |
| Figure 9 - Connecting the Digital Sensor to the Controller .....                | 13 |
| Figure 10 - Connecting the Supply Air Sensor to the Controller.....             | 14 |
| Figure 11 - Connecting the Slab Temperature Sensor to the Controller .....      | 15 |
| Figure 12 - Connecting the Discharge Temperature Sensor to the Controller ..... | 15 |
| Figure 13 - Connecting an External Timer to the Controller.....                 | 16 |
| Figure 14 - Outputs 3 and 4 Active.....                                         | 18 |
| Figure 15 - Output in SINK mode.....                                            | 18 |
| Figure 16 - Connection of Active Outputs 3 and 4.....                           | 18 |
| Figure 17 - Connection of Passive Outputs 3 and 4.....                          | 19 |
| Figure 18 - Connecting the Analog Output (Controller Powered) .....             | 19 |
| Figure 19 - Connecting the Analog Output (External Power) .....                 | 19 |
| Figure 20 - Connecting the 24VAC Power Source.....                              | 20 |
| Figure 21 - Connecting to the Network .....                                     | 20 |
| Figure 22 - C1050 Size Diagram.....                                             | 23 |



### PL-C1050 VAV Zone Controller

#### Description

The Prolon C1050-VAV series zone controllers are designed for variable air volume zoning systems. The built-in microprocessor offers precise digital control to maximize performance. The outputs and control sequences are all fully configurable, either locally or remotely, using free software or from the digital room sensor. The C1050-VAV requires an external actuator (sold separately) when damper control is needed. When in a network, the C1050-VAV can share information such as the occupancy state, the demand, the supply temperature and more.

#### General Behaviour

The Prolon C1050-VAV controllers are configurable so that every parameter may be tuned to obtain optimal results for each zone. It is possible to modify the action of each output (heating or cooling, ON/OFF or pulsed), the proportional bands, the integration times, the differentials, the operational ranges and the setpoints. The various programming options also allow the user to modify the unoccupied mode setpoints, the deadbands, the maximum and minimum setpoints for each zone, as well as the minimum damper positions in ventilation mode and heating mode for each zone. All these parameters can be modified using the Prolon Focus software or with the Prolon digital sensor (T1000 series).





## Operating Sequence

### General

---

The Proton controller, located on the VAV box, receives the zone temperature and setpoints from the zone sensor, and optionally the duct temperature from a duct temperature sensor. The controller then analyzes the information and commands the damper actuator and the different outputs to respond accordingly.

### Occupied Mode

---

When there is a cooling demand in the zone and the supply temperature is colder than the zone temperature, the damper opens proportionally to the demand. Once the demand is satisfied, the damper returns to its minimum ventilation position.

When there is a heating demand in the zone, the controller activates the designated auxiliary heating outputs. If the zone has a terminal duct heater, the damper opens first to the minimum heating position and the designated auxiliary heating outputs activate. If the supply temperature is warmer than the zone temperature, the damper is used as the first heating output and opens proportionally to the demand. Once the demand is satisfied, the damper returns to the minimum ventilation position.

When the controller has no cooling or heating demand (deadband), and the supply temperature is also within this deadband, the controller opens the damper to maximum position to allow maximum ventilation of the zone.

The user can modify the setpoints by adjusting the room temperature sensor at all times.

### Unoccupied Mode

---

In unoccupied mode, the damper can be configured to fully open or to operate in a fashion similar to that of occupied mode. The room temperature setpoints in the unoccupied mode are adjustable.

The digital zone sensors offer a method to temporarily bypass the unoccupied mode for a specified length of time.



PL - C1050 - VAV - **PI**

| Flow Sensor                                                                              |
|------------------------------------------------------------------------------------------|
| BLANK: No Flow Sensor<br>PI: With Flow Sensor 0-2 in.H <sub>2</sub> O (approx. 3500 FPM) |

**Figure 1 - Part Number**

### Flow Sensor

This option specifies whether or not a flow sensor should be included with the C1050 VAV controller.

In all cases, the C1050 includes:

- 2 Independent Communication Ports
- 3 Analog Inputs
- 1 Binary Input
- 4 Configurable Digital Outputs (24 VAC Source or Sink)
- 1 Configurable Analog Output (0-10VDC)

The external damper actuators can be controlled by either the Analog Output (modulating actuator), by Digital Outputs #1 & #2 (floating actuator), or both.



## Component Identification




Figure 2 - Component Identification

### Legend:

- A - Analog Input Signal Mode Jumpers
- B - Addressing dipswitch
- C - Jumpers for terminating and bias resistors for the INT port (see I)
- D - Jumpers for terminating and bias resistors for the NET port (see K)
- E - SOURCE/SINK dipswitch for Output 4
- F - SOURCE/SINK dipswitch for Output 3
- G - SOURCE/SINK dipswitch for Output 2
- H - SOURCE/SINK dipswitch for Output 1
- I - INT port for RS485 communication (terminal block)
- J - Alternate terminal blocks for 24 VAC (provides power to an optional digital sensor)
- K - NET port for RS485 communication (terminal block)
- L - Inputs (4 total)
- M - Terminal Blocks for Outputs 1 to 5
- N - Terminal Blocks for 24 VAC
- O - Airflow Sensor (optional)



## LEDs

The C1050 has various LEDs which are linked to different functions and outputs of the controller. Each LED is individually identified to help the user make a quick visual diagnostic of the controller's activity and status.




Figure 3 - LEDs Identification

## Address Configuration for Networking (*Modbus or BACnet*)

A unique address on each controller must be configured by setting the first 7 switches of the addressing dipswitch to the desired value.

These switches are numbered from 1 to 7 and represent a binary value from 1 to 64 (1, 2, 4, 8, 16, 32, 64 respectively). The value of each switch that is in the ON position is added together to form the numerical address of the controller.

The example on Figure 4 shows the switches 1, 2 and 4 on the ON position. So the corresponding values are 1, 2 and 8, giving an address sum of 11. ( $1+2+8=11$ ).

Modbus and BACnet networks over RS485 allow a maximum of 127 addresses, therefore 127 controllers.

**To enable BACnet communication**, no additional communication card is required! Simply move switch #8 of the addressing dipswitch to the 'ON' position to start BACnet MS/TP (RS485) communication.




Figure 4 - Addressing Dipswitches



## Airflow Sensor (Optional)

Airflow sensors are only included in the PL-C1050-VAV-PI models only. Adding an airflow sensor to the Prolon C1050 lets it regulate the airflow as well as temperature in a zone, independently of the static pressure variations of the system.

The default flow sensor has a range of 0 to 2 in H<sub>2</sub>O (0 to 500 Pa). Depending on the flow cross used, this translates to roughly 0-3500 ft/min.

It is important to connect the airflow tubing in the correct direction, as illustrated in the following diagram:




Figure 5 - Airflow Sensor Inlets



# Damper Direction Configuration

The default damper opening direction of a C1050 VAV controller is counter clockwise (CCW). This parameter can be modified in three different ways. The first is by navigating the menus on the T1000 digital wall sensor, the second is by using the Proton Focus software to manually change the setting. The third is to use the following method:

## 1. Reversing the Damper Direction

Whenever a C1050 resets while a jumper is placed on the last two pins on the far most right of port J11, the damper opening direction will be inverted (see adjacent image).

A C1050 can be **reset** in one of the following ways:

- Device reset via the Proton Focus software
- Cycling power to the device

Please note that in the event of a device reset while using a floating actuator, a C1050 VAV controller always performs a damper recalibration first, where it moves the damper completely to one side and then completely to the other side. Even if you invert the damper opening direction, the change will not take effect until after the calibration period.

**2. Once you have finished** configuring the damper opening direction to the setting of your choice, **do not forget to REMOVE the jumper** from the last two pins, or the damper direction will invert itself again and again upon any subsequent resets of the controller.

To ensure that the damper direction will no longer change, move the jumper one pin to the left, as depicted in this image:

## 3. Confirming Damper Direction

The damper opening direction can be visually confirmed by observing the yellow “STAT” LED on the VC1050 board after performing a **reset**:

- “STAT” LED STEADY ON for 3 seconds = COUNTER CLOCKWISE (CCW) OPENING
- “STAT” LED PULSES 3 TIMES (ON/OFF) over 3 seconds = CLOCKWISE (CW) OPENING




Figure 6 - Damper Configuration



## Input and Output Identification

All the inputs and outputs of the C1050 use pluggable screw type terminal blocks with elevator style clamping, which make connections easier and more secure. The C1050 VAVController has two separate communication ports offering the same functionality on each. Both act as ports for incoming Modbus communications from other Prolon devices or interfaces, such as a Network Controller or remote computer with Prolon Focus software.




Figure 7 - Input and Output Identification



## Room Sensors

Two types of room temperature sensors are available:

- **Analog:** Analog room temperature sensor (thermistor) with setpoint knob and override button
- **Digital:** Digital sensor, communicating over RS485 to the C1050

### Analog Room Sensor (PL-RS Series)

The PL-RS series room sensors provide the C1050-VAV with a room temperature and setpoint. A push-button is also present to override the schedule. The PL-RS series are connected using a 3-conductor cable. Note that if a shielded cable is used to connect the PL-RS, the shield must be grounded at the GND (pin 1) of the C1050 to which it is connected. To activate the schedule override from the PL-RS, hold the override button for 3 seconds.





Figure 8 - Typical Wiring of the PL-RSC Room Sensor to the Controller

### Digital Room Sensors

ProLon offers various digital communicating sensors that can provide the C1050 with room temperature, room setpoint, and schedule override (T1000, T500, T200 sensors), as well as giving you access to all configuration parameters of the C1050 (T1000 only).

For your convenience, an additional set of 24 VAC and COM pins are provided to simplify the wiring and powering of a digital sensor. Please note that since the digital sensor pulls its power from the C1050, it is important to take the power requirements of the digital sensor into account when selecting a power source for the C1050.

The communication protocol for this port is exclusively Modbus RTU. Typical wiring is as follows:



**Figure 9 - Connecting the Digital Sensor to the Controller**



## Multi-Function Analog Input

The C1050 has a multi-function analog input. The function of this input varies depending on the configuration that is setup using the Proton Focus software. By default, this input is used as a supply air temperature input.

### Supply Air Temperature Sensor (PL-CODS)

When a zone controller works autonomously, a supply air temperature sensor (10K Type 3) can be connected to it in order to invert the damper control method upon detection of hot or cold air.

However, if that controller is part of a network that includes a Proton Master controller (RTU, HP or other), individual sensors for each C1050 may be unnecessary since the Master controller will distribute its own supply air temperature reading to all controllers it is associated with.

**NOTE:** A supply temperature reading received from a physically attached thermistor will take precedence over a reading received over the network.

If no Master is present and no sensor is available, the controller will then work under the assumption that there is cold air in the supply. Alternatively, by shorting the supply temperature input (terminals 15 and 16), the controller will instead assume there is hot air in the supply.





Figure 10 - Connecting the Supply Air Sensor to the Controller

### Radiant Floor Slab Temperature Sensor

When the C1050 is configured to work as a radiant floor controller, the function of the supply temperature input changes to become a slab temperature input. Therefore, a radiant floor slab thermistor (10K type 3) can then be connected to the C1050 on terminals 15 and 16 (see Figure 11).


Note that if a T1000 digital sensor is connected to the C1050, the slab thermistor can instead be wired directly to the T1000, which will then send both space and slab temperatures to the C1050, cutting down wiring costs. The supply temperature input can then again be used for a supply air sensor or other.



**Figure 11 - Connecting the Slab Temperature Sensor to the Controller**

## Discharge Air Temperature Sensor

The multi-function analog input can be configured to monitor a discharge air temperature sensor (10K type 3). Discharge air temperature is not used in any sequence and is for display purposes only.



**Figure 12 - Connecting the Discharge Temperature Sensor to the Controller**



## Digital Input

### Occupancy originating from an External Timer

An external timer can be used to switch the C1050 between occupied and unoccupied modes. The dry contact originating from the external timer must be connected to the "Setback" and the "GND" terminals (17 and 15). Refer to Figure 13 to see how to correctly connect the timer.

To indicate occupied mode, the contact must be open. To indicate unoccupied mode, the contact must be closed.

Note that if a C1050 controller is part of a network that includes a Proton Master controller (RTU, HP or other), an individual contact per C1050 may be unnecessary because all zone controllers share the occupancy status sent on the network by that Master.

**NOTE:** The occupancy state received from a physically attached dry contact will take precedence over the occupancy state received over the network. Applies only to closed contact (unoccupied mode).




Figure 13 - Connecting an External Timer to the Controller

### Standby mode originating from a Motion Detector

A motion detector is typically used to enable the standby mode sequence. The dry contact originating from the motion detector must be connected to the "Setback" and the "GND" terminals (17 and 15). Refer to Figure 13 to see how to correctly connect the motion detector, it is similar to an external timer.

To indicate occupancy in the space (motion detected), the contact must be closed. Standby mode occurs when the C1050 is receiving an occupancy signal from the network, but no motion is detected in the space (contact open).

When in standby mode, the controller uses an alternate, smaller damper minimum position, and will also stop influencing the master controller in regards to building demand (zone demand and weight sent to the master are 0). The C1050 will still control its own space to the best of its ability.



## Outputs

The C1050 series controllers are equipped with four configurable 24VAC triac digital output and an analog 0-10VDC output to control a wide variety of equipment. All outputs are fully configurable in either heating or cooling mode, can function in pulsed or ON/OFF mode, and much more. The entire setup for each output is fully customizable via the ProLon Focus software or the ProLon T1000 digital sensor.

An integrated resettable fuse protects **each** of the outputs of the C1050 against current surges and short circuits. This protection will cut the current to the output as soon as an overload condition is detected. The fuse is round and yellow-colored which, upon a short circuit condition, will heat up and change to orange. When the faulty wiring or circuit is fixed, the fuse will automatically reset and allow current to flow through the output again.

The analog output is equipped with a diode so that it can be wired in parallel with the analog outputs of other VC2000s to obtain a “highest voltage” signal.

## Output Specifications

| Output | Type                                                                                                                                    | Heating                                                        | Cooling                                        |
|--------|-----------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------|------------------------------------------------|
| 1      | Triac Source 24VAC<br>Passive Triac (dry contact)<br>On-or-Off<br>Pulsed<br>Max Current: 300mA                                          | Damper<br>Valve<br>Relay<br>Triac                              | Damper<br>Valve<br>Relay                       |
| 2      | Triac Source 24VAC<br>Passive Triac (dry contact)<br>On-or-Off<br>Pulsed<br>Max Current: 300mA                                          | Damper<br>Valve<br>Relay<br>Triac                              | Damper<br>Valve<br>Relay                       |
| 3      | Triac Source 24VAC<br>Passive Triac (dry contact)<br>On-or-Off<br>Pulsed<br>Max Current: 300mA                                          | Valve<br>relay<br>Triac                                        | Valve<br>Relay                                 |
| 4      | Triac Source 24VAC<br>Passive Triac (dry contact)<br>On-or-Off<br>Pulsed<br>Max Current: 300mA                                          | Valve<br>Relay<br>Triac                                        | Valve<br>Relay                                 |
| 5      | Modulating Output<br>On-or-Off<br>Pulsed<br>Max Current: 40mA<br>Configurable Signal:<br>- 0 to 10 VDC<br>- 2 to 10 VDC<br>- 0 to 5 VDC | Modulating Damper<br>Modulating Valve<br>SCR<br>Relay<br>Triac | Modulating Damper<br>Modulating Valve<br>Relay |



## Configuration of Digital Outputs 1 to 4

Outputs 1 to 4 are configurable via switches located on the C1050 board. Simply move the switch to obtain either an active output (1) or a passive output (2).

### 1) Switch position to obtain an **active output**:




Figure 14 - Outputs 3 and 4 Active

### 2) Switch position to obtain a **passive output**:




Figure 15 - Output in SINK mode

## Typical Connection of the Triac Outputs 1 to 4

Two types of configurations are possible:

### 1) Active outputs. The C1050 is actively powering the load.




Figure 16 - Connection of Active Outputs 3 and 4



2) Passive outputs. The C1050 opens and closes a contact to allow an external source to power the load.




Figure 17 - Connection of Passive Outputs 3 and 4

## Typical Connection of the Analog Output

Two types of configuration are possible:

1) The C1050 powers the load and provides a control signal.




Figure 18 - Connecting the Analog Output (Controller Powered)

2) The C1050 only provides the control signal to the load, which is powered by an external source.




Figure 19 - Connecting the Analog Output (External Power)



The Proton C1050 controller is powered by a 24 VAC power source (Class 2) connected using the "COM" terminal and the "24 VAC" terminal. The common for all inputs and outputs are the same as the power source's common (exception: when an output is set to passive, the common for this output will not correspond to the power source common). All output power sources also originate from the controller's power source. Note that if a digital sensor is being powered by the C1050, it is important to take the power requirements of the digital sensor into account when selecting a power source for the C1050.



The ProLon C1050 controller works autonomously or networked. When networked, it will communicate in real-time with other controllers. The C1050 controller's default communication protocol is Modbus RTU over RS485. The addressing is done with the addressing dipswitch located on the C1050 card (see Figure 4). The network connections are made using the NET terminal block located on the ProLon C1050 controller. If the optional Lon communication card is connected to the C1050 board, the controller will automatically switch to the Lon protocol, with a unique address found on the communication card itself.





## Technical Specifications

**Supply:** 24 VAC  $\pm 10\%$ , 50/60 Hz, Class 2

**Consumption:** 3 VA (Typ Consumption), 5 VA (Max Consumption), 24 VA (Input)

**Inputs:**

- Room – thermistor 10K
- Duct – thermistor 10K
- Setpoint – potentiometer 0-10K
- Optional flow sensor
- External clock – dry contact
- Override – dry contact
- Digital room sensor

**Flow sensor:** 0-2 inches of H2O (optional)

**Digital outputs:** 1 triac 10-30 VAC dry contact, 300 mA max (resettable fuse), ON/OFF or pulsed, heating or cooling

**Analog output:** 0-10 VDC, 40 mA max (resettable fuse), modulating, ON/OFF or pulsed, heating/cooling

**Indication lights (LED):** State of each output / Communication / Power / State of microprocessor

**Microprocessor:** PIC18F6722, 8 bits, 40 MHz, 128KB FLASH memory

**Casing:** Molded ABS, UL94-HB

**Communication:** 1x Modbus RTU (RS485) or BACnet MS/TP (RS485) up to 127 nodes, 1 RS485 port for digital sensor or computer interface

**Baud rate:** 9600, 19200, 38400, 57600, 76800, 115200

**Connection:** Removable screw-type terminal blocks (16 AWG max)

**Dimensions:** 5" x 5" x 3" (127 mm x 127 mm x 77 mm)

**Weight:** 1.15 lbs (0.5 kg)

**Environment:** 32-122 °F (0-50 °C) Non-Condensing

**Certification:** UL916 Energy Management Equipment, CAN / CSA-C22.2, FCC part 15: 2012 class B, RoHS

*The performance specifications are nominal and conform to acceptable industry standards. Prolon Inc. will not be liable for damages resulting from misapplication or misuse of its products.*



## Compliance

- FCC Compliant to CFR47, Part 15, Subpart B, Class B
- Industry Canada (IC) Compliant to ICES-003, Issue 5: CAN ICES-3 (B)/NMB-3(B)
- RoHS Directive (2002/95/EC)

### FCC User Information

---

This device complies with Part 15 of the FCC Rules. Operation is subject to the following two conditions: (1) this device may not cause harmful interference, and (2) this device must accept any interference received, including interference that may cause undesired operation.

**Caution:** Any changes or modifications not approved by Proton can void the user's authority to operate the equipment.

**Note:** This equipment has been tested and found to comply with the limits for a Class B digital device, pursuant to part 15 of the FCC Rules. These limits are designed to provide reasonable protection against harmful interference in a residential installation. This equipment generates, uses and can radiate radio frequency energy and, if not installed and used in accordance with the instructions, may cause harmful interference to radio communications. However, there is no guarantee that interference will not occur in a particular installation. If this equipment does cause harmful interference to radio or television reception, which can be determined by turning the equipment off and on, the user is encouraged to try to correct the interference by one or more of the following measures:

- Reorient or relocate the receiving antenna.
- Increase the separation between the equipment and receiver.
- Connect the equipment into an outlet on a circuit different from that to which the receiver is connected.
- Consult the dealer or an experienced radio/TV technician for help.

### Industry Canada

---

This Class (B) digital apparatus meets all the requirements of the Canadian Interference-Causing Equipment regulations.

Cet appareil numérique de la Classe (B) respecte toutes les exigences du Règlement sur le matériel brouilleur du Canada.



No part of this document may be photocopied or reproduced by any means, or translated to another language without prior written consent of Prolon. All specifications are nominal and may change as design improvements are introduced. Prolon shall not be liable for damages resulting from misapplication or misuse of its products. All trademarks are the property of their respective owners.